



LAPI LABORATORIO PREVENZIONE INCENDI S.p.A.
 Sede Primaria: I-59100 PRATO - Via della Quercia, 11
 Telefono +39 0574.575.320 - Telefax +39 0574.575.323
 Sede Secondaria: I-50041 CALENZANO (FI) - Via Petrarca, 48
 e. mail: lapl@laboratoriolapi.it
 web site: www.laboratoriolapi.it

Notified Body N°0987
Directive 89/106 CEE



EC - Certificate of Conformity 0987-cpd-078

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of law, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that:

the building product denominated:

LAMCO HPL COMPACT AE

Description of the product:

**HPL laminate used as wall and ceiling internal covering / finishing,
thickness from 3.0 to 6.0 mm enclosed, various colours**

Type: **HPL laminate**

Use: **internal covering / finishing of wall-ceiling mounted on aluminium tubular rods**

Produced by:

LAMICOLOR S.p.A.

Via Roma, 23 - 12030 CARAMAGNA P. TE (CN) - ITALY

In the factory of.

Via Roma, 23 - 12030 CARAMAGNA P. TE (CN) - ITALY

is submitted by the manufacturer to the factory production control (FPC) according to AoC 1 and to the testing of samples (ITT) by the Notified body for Certification, Inspection and Testing according to Directive 89/106 CEE.

The Notified Body (**LAPI SpA - Laboratorio Prevenzione Incendi N° 0987**) has performed the initial type testing on the samples taken at the factory in accordance with the described test for the relevant characteristics of the product, the initial inspection of the factory and the factory production control and it will perform the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the Attestation of Conformity System AoC 1 and the performances described in Annex ZA of the standard

EN 438 - 7: 2005

**High-pressure decorative laminates (HPL) - Sheets based on thermosetting resins (usually called laminates)
Part 7: Compact laminate and HPL composite panels for internal and external wall and ceiling finishes**

are performed and the product complies with characteristics required as for:


Release of formaldehyde class: E1
 Resistance to fixing: 260 N (thickness 2 mm) : 1000 N (thickness 4 mm) : 2000 N (thickness 6 mm)
 Durability: PASSEs

Moreover Euroclass for reaction to fire according to EN 13501-1:2001 is:

B-s2, d0

This result is valid in the following conditions:

- Internal use.
- Mounted on tubular aluminium rods without interposition of insulating layer.



This certificate is issued on 10/07/2007 and it remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or as long as the factory production control itself are not modified significantly and latest on 10/07/2012



The Director
 D. Gian Carlo Borsini
Gian Carlo Borsini